Department of Public Safety
Division of Fire and Life Safety
Proposed 2012 Code or A.A.C. Request

5700 E. Tudor Road
Anchorage, Alaska 99507
(907) 269-5491 Fax: (907) 338-4375

REQUESTING AGENCY INFORMATION

Name: Jill Roberts & Dave Aden	**Business Name:** **SOA**
Address: **5700 E Tudor Rd** **City: Anchorage ST: AK Zip: 99507** **Phone:269-2004**	**Email:** Jillian.roberts@alaska.gov David.aden@alaska.gov

2012 Code or A.A.C. Reference Site:

PROPOSED CHANGE: Amendment # 65 to IBC Table 1018.1 change the new item (1) to read: (1) serves four or fewer dwelling units or 16 or fewer sleeping rooms.

Also make the same change to IFC Table 1018.1

Legislative format, bold underline new language and bracket and capitalize deletions

EXPLANATION of why proposed changes should be made to the 2012 Code or A.A.C.: This will match the wording used in the new 903.2.8.2 which dictates when an R2 must be sprinklered. The current wording leaves us wondering what to do with corridors in R2 occupancies with 4 dwelling units or 16 sleeping rooms.

6-15-16

Review action, Approved, As Submitted LMNØ As Modified_____ Defeated_____