



Division of Fire and Life Safety
Life Safety Inspection Bureau

5700 East Tudor Road, Anchorage, Alaska 99507

Phone: (907) 269-5637 | Fax: (907) 269-5018 | Email: amy.noket@alaska.gov

Application for Fireworks Permit

(Authority 2009 IFC Chapter 33, 13AAC 50.025 (74) – (84), and AS 18.72.020 – 040)

Retail

APPLICANT INFORMATION			APPLICANT BUSINESS INFORMATION		
Applicant Legal Name:			Business Name:		
Phone:	Date of Birth:	Social Security #:	Phone:		
Mailing Address:			Mailing Address:		
City:	State:	Zip Code:	City:	State:	Zip Code:

WHOLESALER INFORMATION		RETAIL STAND LOCATION INFORMATION		
Wholesaler Name:		Physical Location:		
Phone:	Permit #:	City:	State:	Zip Code:
Address:		INSURANCE INFORMATION Per AS 18.72.020 (a) a policy or certified true copy of a policy of public liability and products liability insurance provided by the wholesale company is attached.		
City:	State:	Zip Code:	Expiration date of liability insurance:	

APPLICANT ACKNOWLEDGMENT		NOTARY USE	
<p><i>I acknowledge and agree to the following:</i></p> <ul style="list-style-type: none"> • Presently the fee for these permits is \$10.00 and must be paid every TWO (2) years; <i>and</i> • Permits are issued to the person listed on the application and not the name of a company; <i>and</i> • I have read and understand Section 13AAC 50.025 (74) – (84); <i>and</i> • Permits are only valid during the dates of my liability insurance; <i>and</i> • The State of Alaska, Department of Transportation will not permit stand to be located on State Highway Right-of-way, i.e. 150 feet from the centerline; <i>and</i> • I further certify the information supplied on this application is true and accurate to the best of my knowledge 		Subscribed and sworn to before me on this day:	
Applicant Signature		Notary Public in and for:	
Date	My Commission Expires:		
		Seal	

LSIB OFFICIAL USE		
Date received in office:	Processed date:	Permit #:
Receipt #:	Next fee due:	

ADDITIONAL REQUIRED DOCUMENTS

Presently the fee for these permits is \$10.00 and must be paid every TWO (2) years. Your permit is ONLY valid during the dates of your liability insurance. Please make checks payable to the State of Alaska and attach the following required documents:

1. A policy or certified true copy of a policy of public liability and products liability insurance of at least \$200,000 for bodily injury or death and at least \$50,000 for property damage. The applicant must be the person named on the insurance policy. Faxed or email copies from the insurance companies will be accepted.
2. Map of stand location; including construction and distance to any storage magazines and nearby buildings. The stand must be 250 feet from residential and public assembly buildings, and 150 feet from the centerline of ANY state highway. At least two exits must be provided, indicated on a diagram of the proposed stand.

Chapter 33 of the IFC is revised by the addition of Subsection 3308.6.1, which reads: "Mortar construction: Mortars must be constructed of heavy cardboard, paper, high density plastic pipe, or metal other than cast iron." And Subsection 3308.11, which reads: "3308.11 Retail sales of saleable fireworks: Retail sales of saleable fireworks as described in AS 18.72 must be made in accordance with this section.

3308.11.1 - Dedicated structure or stand:

Saleable fireworks may be sold only from a dedicated structure or stand that has a minimum of two exits meeting Chapter 10 of the IBC. Exception: Structure meeting the criteria of a group H-1 occupancy as established by the IBC are exempt from the requirements of Subsection 3308.11.1.

A DIAGRAM OF THE STAND MUST BE INCLUDED WITH THE PERMIT APPLICATION, INCLUDING DETAILS OF EXITING AND STORAGE OF ANY EXCESS FIREWORKS.

3308.11.2 - Fire Extinguishers:

Portable fire extinguishers that meet the criteria of Subsection 906.2 must be provided.

DESCRIPTION/LOCATION OF FIRE EXTINGUISHER ON SITE: _____

3308.11.3 - Placard:

A placard setting out the language of AS 41.15.070, 41.15.140, and 41.15.160 must be prominently displayed.

3308.11.4 - Sales:

The sale of saleable fireworks may not take place within 250 feet of a place of residence or public assembly.

3308.11.5 - Class B dangerous fireworks:

Class B dangerous fireworks may not be stored or offered for sale at a retail sales location.

3308.11.6 - Use or discharge:

Fireworks of any class may not be used or discharged with 250 feet (76.2 m) of a retail sales location.

3308.11.7 - Right-of-way:

Retail sales locations may not be located on a highway or utility right of way.

3308.11.8 - Display of permit or license:

The retail sales permit or license shall be conspicuously displayed, at the sales location.

3308.11.9 - Age of employee:

A person under the age of 18 years may not be employed where fireworks are sold or stored.

3308.11.10 - Age of purchase:

Fireworks may not be sold to a person who is or appears to be under the age of 18 years.

3308.11.11 - Prohibition:

Fireworks may not be sold to a person who is or appears to be intoxicated or otherwise chemically impaired. **3308.11.12 - Storage:**

Saleable fireworks, class 1.4 G (Class C common fireworks) must be stored as follows:

1. Storage at retail sites must be in a type 4 or higher rated magazine;
2. Except as provided in paragraph 3 of Subsection 3308.11.12, storage must be a minimum of 40 feet from property lines or any inhabited building. The dedicated structure or stand used for selling fireworks is excluded;
3. Storage must be a minimum of 250 feet from a place of residence or public assembly building;
4. Storage may not be located on a highway or utility right of way;
5. Storage at any site except approved retail locations must be in accordance with the requirements for low explosives in Subsection 3304.3.2.

NOTE: For storage of more than 5000 lbs. of explosive material, the minimum distance requirements from buildings and highways may be increased. Reference the Uniform Fire Code Article 78 Section 7801.5.12 or contact the State Fire Marshal's office.

3308.11.13 - Permitted sales locations:

All saleable fireworks must be sold from the location specified in the permit application.

3308.11.14 - Suspension of sales and use:

The sale or use of fireworks may be suspended by the state fire marshal in any area where the Department of Natural Resources has declared the wild fire danger to be extreme.

I have read the fireworks regulations listed above and understand that if I do not abide by these regulations my permit will be disapproved or revoked.

By signing this application you are making a sworn statement that you are aware of and abiding by the laws regarding the purchase, transportation, sell and storage of 1.4G fireworks.

Applicant Signature	Date
---------------------	------

There will be no rushes on Retail Permits. Please be responsible and plan ahead. You will receive your permit within two weeks of our office receiving all required and accurate documentations.

**TITLE 41. PUBLIC RESOURCES
Article 01. PROTECTION OF FORESTED LAND**

Section 41.15.070 - DISPOSAL OF BURNING MATERIALS:

A person who, during the fire season, throws away lighted tobacco, cigar, cigarette, match, firecracker, or other burning material on forested land, whether public or private, is guilty of a misdemeanor.

Section 41.15.140 - PENALTY OF MISDEMEANOR:

A person who is convicted of a misdemeanor under AS 41.15.010 - 41.15.170 is punishable by a fine of not less than \$25 or more than \$500, or by imprisonment in jail for not less than 10 days or more than six months, or by both.

Section 41.15.160 - DOUBLE DAMAGES IN CIVIL ACTIONS:

In addition to the criminal punishment provided for by AS 41.15.010 - 41.15.170, the United States, the state, a municipality, or any person may recover in a civil action double the amount of damages sustained as a consequence of a violation of AS 41.15.010-41.15.170. In a civil action brought under AS 41.15.010-41.15.170 or any other law relating to the subject matter of AS 41.15.010-41.15.170, the escape of a fire is presumptive evidence of negligence by the person responsible for starting the fire and unless rebutted is sufficient to sustain the recovery.