

# AUTHORIZATION TO MARK

Date: 3, March 2004

tlr

This authorizes Pump Measure Control, Inc. to apply the ETL mark shown below to the Products Covered when made in accordance with the Description and under the conditions set forth in the Certification Agreement and Listing Report:

**Applicant:** Pump Measure Control, Inc.  
1070 Nine North Drive, Suite 100  
Alpharetta, GA 30004

**Contact:** Mr. Grant Grove **Phone:** 770-667-0667 **Fax:** 770-667-0476

**Manufacturer:** Same as applicant

**Party Authorized To Apply Mark:** Same as applicant

**Report Issuing Office:** Intertek Testing Services  
ETL SEMKO  
3933 US Route 11, Industrial Park  
Cortland, NY 13045

**Reference Report No.:** 3041582-H01

**Product Covered:** **Petroleum fuel dispenser models:** Petroleum fuel dispenser models: CMD-501-XX, CMD-502-XX, CMD-701-XX, CMD-702-XX, CMD-1500-XX, FH-510-XX-YZ, FH-515-XX-YZ, and FH-720-XX-YZ where XX can be MA, AV or GS, Y can be 1, 2, 3, 4, or 5, and Z can be M, A or G.

**Description:** This products covered by this report are dispensers intended to be used with petroleum based fuel. Each dispenser is permanently mounted in place and permanently connected to the electrical and fuel supply. The dispensers are divided in to two distinct classified environments. The lower portion where fuel is handled is a Class I, Division 1, Group D location, and the electronics cabinet above is an unclassified location. The separation between the two environments is made by the use of a solid plenum (vapor barrier) between the fuel handling and electronics cabinets.

**Standard(s):** Power-Operated Dispensing Devices for Petroleum Products, UL-87 Eleventh Edition, Oct. 31, 2001 and Control Equipment for Use with Flammable Liquid Dispensing Devices, UL-1238 Third Edition, Sept. 28, 2001.

This document is the property of Intertek Testing Services and is not transferable. Only the Applicant may reproduce this document. The certification marks may be applied only at the above noted location of the Party Authorized to Apply Mark.



Authorized by:

*William T. Starr*

Date:

*March 16, 2004*

William T. Starr

Certification Manager

Control Number:

*601047*

Intertek Testing Services NA Inc.  
165 Main Street, Cortland, NY 13045  
Telephone 800-345-3851 or 607-753-6711 Fax 607-756-6699