

**In Field Instrument Review 7/18/2017-09/30/2017**

100345 (AST Soldotna): 2/37 RFI- No action taken

100346 (Fairbanks Airport): 2/6 RFI- No action taken

100347 (Craig PD): 5/18 Tank Interference- All occurred on 7/30/2017 and no problems since. Will watch.

100349 (Ketchikan PD): 1/14 RFI, 3/14 Pump Error- No action taken

100350 (APD): 1/112 Pump Error, 14/112 Interference, 1/112 Blank Error, 1/112 Gas Flow Error. Removed from service for Interference Detected.

100352 (Anchorage Airport PD): 1/4 Pump Error- No action taken

100355 (Seward PD): 1/21 RFI, 1/21 Tank Interference- No action taken

100356 (Skagway PD): 1/18 RFI, 1/18 Tank Interference, 1/18 Blank Error, 1/18 Internal Standard Error- Continue to monitor.

100361 (Unalaska PD): 1/6 RFI, 1/6 Pump Error- No action taken

100363 (Nome PD): 1/16 Pump Error, 1/16 Interference- No action taken

100365 (North Pole PD): 1/17 Tank Interference- No action taken

100367 (Palmer PD): 1/47 Pump Error 1/47 Filter Wheel Error- Removed from service for Filter Wheel Error

100370 (Homer PD): 2/17 RFI- Removed from service for preventative maintenance

100376 (Metlakatla PD): 1/7 Pump Error- No action taken

100378 (AST Fairbanks): 3/41 RFI, 1/41 Pump Error- No action taken

100384 (Juneau PD): 1/33 Tank Interference- No action taken

100396 (APD): 1/101 Pump Error, 1/101 Blank Error, 1/101 Ambient Fail, 1/101 Internal Standard Error- No action taken

100400 (NSBPD): 2/6 Standard Out of Range- Out of Service for Detector Overflow

100405 (Dillingham PD): 2/12 Interference- No action taken

100406 (SCDL): Instrument was not in service during this time. Tests were from training at laboratory.

100413 (Homer PD): 1/9 RFI- No action taken

100414 (Eielson AFB): 1/3 Blank Error- No action taken

100415 (Sitka PD): 3/22 RFI, 1/22 Blank Error, 2/22 Diagnostic Failed- No action taken

100416 (Fairbanks PD): 2/42 RFI- No action taken

100421 (JBER): 4/74 RFI, 4/74 Interference, 1/74 Blank Error, 4/74 Diagnostic Failed, 7/74 Static Analysis Error- Recommend Remove from Service

100665 (AST/Angoona): 1/2 Pump Error- No action taken

100667 (AST/MatsuWest): 1/14 RFI- No action taken

100669 (APD): 1/45 Interference- No action taken

100674 (Juneau PD): 1/10 RFI, 1/10 Ambient Fail- No action taken

100676 (AST/Cantwell): 1/3 RFI- No action taken

100678 (AST/Anchor Point): 1/7 Interference- No action taken

100681 (Whittier PD): 2/4 Blank Error, 1/4 Standard Out of Range- No action taken

100683 (AST/Glennallen): 1/9 RFI- No action taken

100685 (AST/Tok): 1/9 RFI, 2/9 Blank Error, 1/9 Internal Standard Error- No action taken

100691 (Valdez PD): 1/6 Pump Error- No action taken

100695 (Wasilla PD): 4/42 RFI, 1/42 Pump Error, 1/42 Blank Error- No action taken

100698 (Kenai PD): 1/14 Tank Interference-No action taken



